



SEAL360 PREMIUM GLAZING SILICONE

100% NEUTRAL CURE

Updated: 21/09/2017

Re: VOC STATEMENT

The following products have been tested in accordance with the Californian South Coast Air Quality Management rule 1168 and the results are as follows:



Product Name	Product Code	TVOC (g/l)	TVOC %	SCAQMD Product Type
Seal360 Translucent	10SE360TR	20g/L	2.0%	Architectural Sealant
Seal360 Matt Black	10SE360MB	38g/L	3.8%	

- SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.
- Note: TVOC = Total volatile organic compounds. VOC = TVOC less exempt compounds. VOC will always be less or equal to TVOC

Allfasteners® Head Office
78-84 Logistics Street Keilor Park VIC 3042 Australia +61 3 9330 0555

Allfasteners Pty Ltd. ACN 113 948 100 ABN 86 766 075 300

www.allfasteners.com.au | Customer Service 1800 255 349